



MONO COUNTY DEPARTMENT OF PUBLIC WORKS

POST OFFICE BOX 457 • 74 NORTH SCHOOL STREET • BRIDGEPORT, CALIFORNIA 93517
760.932.5440 • Fax 760.932.5441 • monopw@mono.ca.gov • www.monocounty.ca.gov

ADDENDUM NO. 1

To the
PROJECT MANUAL, PLANS, SPECIFICATIONS, AND CONTRACT DOCUMENTS
For the
**MONO COUNTY DEPARTMENT OF PUBLIC WORKS
LEE VINING STREETS REHABILITATION PROJECT**
Project No. RPL-5947(034)

ISSUED ON: April 3, 2013

TO: Planholders and prospective bidders for Mono County Department of Public Works Lee Vining Streets Rehabilitation Project

FROM: Mono County Department of Public Works

The following changes or additions shall be made to the Project Manual.

1. Page TS-5 of the Technical Specifications – Section 4, entitled “EROSION CONTROL” shall be amended to include:

Work under this item will include all labor, materials, equipment, and incidentals necessary to **prepare a Stormwater Pollution Prevention Plan (SWPPP) in accordance with the latest Caltrans template** and complete the work as specified to install **and maintain** all necessary erosion control best management practices (BMPs) as described in the SWPPP. **Because the sediment risk is low and the receiving water risk is also low, the Project Combined Risk is Level 1 and storm effluent sampling is not required.**

2. Page TS-12 through TS-14 of the Technical Specifications – Specification for Portland Cement Concrete in Sections 13, 14, 15, 16, and 17 shall read:

Portland Cement Concrete shall conform to the requirements of Section ~~90-10~~ **90-2** “Minor Concrete,” **Section 90-1.02I “Concrete in Freeze-Thaw Areas,”** and Section 73 “Concrete Curbs and Sidewalks” of the State Standard Specifications and these Technical Specifications.

Concrete shall be Class 1 concrete with a minimum 28-day compressive strength of 5,000 psi (all unexposed concrete may be 3,000 psi). Fibermesh fiber additive or approved equal shall be added for all concrete with an exposed wearing surface. Cement for all concrete in the project shall be Type II Portland cement. The maximum water cement ratio shall be 0.45. All concrete shall have an air

entrainment between four (4) percent and six (6) percent. (+0.1%) Coarse aggregate for concrete shall be 1-inch minimum per Section 90-3.02.


3. Page TS-17 of the Technical Specifications – Section 23, entitled “SIGNS AND SIGN POSTS” shall be amended to include:

Sign posts shall be 4” x 4” wood posts installed per Standard Plan RS2.

End of Addendum No. 1

Please forward this addendum if you have given your copy of the contract documents to another party.
Bidder must acknowledge receipt of this addendum on page BD-9 of the Proposal Form.

MONO COUNTY DEPARTMENT OF PUBLIC WORKS



Garrett Higerd, PE
Senior Engineer